

## The Water We Drink

### CITY OF BROUSSARD WATER SYSTEM

Public Water Supply ID: LA1055003

We are pleased to present to you the Annual Water Quality Report for the year 2024. This report is designed to inform you about the quality of your water and services we deliver to you every day (Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien). Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

Our water source(s) are listed below:

| Source Name                   | Source Water Type |
|-------------------------------|-------------------|
| PURCHASE FROM 1055017 LUS     | Ground water      |
| PURCHASE FROM 1055017 LUS     | Ground water      |
| PURCHASE FROM 1055017 LUS     | Ground water      |
| PURCHASE FROM 1055017 LUS     | Ground water      |
| WELL #5 - CNR MONROE AND POLK | Ground water      |

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

Microbial Contaminants - such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic Contaminants - such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and Herbicides - which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

Organic Chemical Contaminants - including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

Radioactive Contaminants - which can be naturally-occurring or be the result of oil and gas production and mining activities.

A Source Water Assessment Plan (SWAP) is now available from our office. This plan is an assessment of a delineated area around our listed sources through which contaminants, if present, could migrate and reach our source water. It also includes an inventory of potential sources of contamination within the delineated area, and a determination of the water supply's susceptibility to contamination by the identified potential sources. According to the Source Water Assessment Plan, our water system had a susceptibility rating of 'MEDIUM'. If you would like to review the Source Water Assessment Plan, please feel free to contact our office.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health. We want our valued customers to be informed about their water utility. If you have any questions about this report, want to attend any scheduled meetings, or simply want to learn more about your drinking water, please contact RAY BOURQUE at 337-837-6681.

*Unregulated contaminants are those that do not yet have a drinking water standard set by USEPA. The purpose of monitoring for these contaminants is to help USEPA decide whether the contaminants should have a standard.*

| Unregulated Contaminants | Collection Date | Average Concentration | Range     | Unit |
|--------------------------|-----------------|-----------------------|-----------|------|
| Lithium                  | 2024            | 40.3                  | 34.0-46.6 | ppb  |

There is no safe level of lead in drinking water. Exposure to lead in drinking water can cause serious health effects in all age groups, especially pregnant people, infants (both formula-fed and breastfed), and young children. Some of the health effects to infants and children include decreases in IQ and attention span. Lead exposure can also result in new or worsened learning and behavior problems. The children of people who are exposed to lead before or during pregnancy may be at increased risk of these harmful health effects. Adults have increased risks of heart disease, high blood pressure, kidney or nervous system problems. Contact your health care provider for more information about your risks.

The Louisiana Department of Health and Hospitals - Office of Public Health routinely monitors for constituents in your drinking water according to Federal and State laws. The tables that follow show the results of our monitoring during the period of January 1st to December 31st, 2024. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk.

In the tables below, you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms, we've provided the following definitions:

Parts per million (ppm) or Milligrams per liter (mg/L) – one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter (ug/L) – one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) – picocuries per liter is a measure of the radioactivity in water.

Treatment Technique (TT) – an enforceable procedure or level of technological performance which public water systems must follow to ensure control of a contaminant.

Action level (AL) – the concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.

Maximum contaminant level (MCL) – the “Maximum Allowed” MCL is the highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as feasible using the best available treatment technology.

**Maximum contaminant level goal (MCLG)** – the “Goal” is the level of a contaminant in drinking water below which there is no known or expected risk to human health. MCLG’s allow for a margin of safety.

**Maximum residual disinfectant level (MRDL)** – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum residual disinfectant level goal (MRDLG)** – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Level 1 assessment** – A study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

**Level 2 Assessment** – A very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Our water system tested a minimum of 6 sample(s) per month in accordance with the Total Coliform Rule for microbiological contaminants. With the microbiological samples collected, the water system collects disinfectant residuals to ensure control of microbial growth.

| Disinfectant | Date | Highest RAA | Unit | Range      | MRDL | MRDLG | Typical Source                          |
|--------------|------|-------------|------|------------|------|-------|---|
| CHLORINE     | 2024 | 1.2         | ppm  | 0.0 - 1.84 | 4    | 4     | Water additive used to control microbes |

In the tables below, we have shown the regulated contaminants that were detected. Chemical Sampling of our drinking water may not be required on an annual basis; therefore, information provided in this table refers back to the latest year of chemical sampling results.

The State of Louisiana regularly monitors source water per State and Federal Regulations. Treated water samples are monitored to further evaluate compliance.

| Disinfection Byproducts       | Sample Point       | Period      | Highest LRAA | Range       | Unit | MCL | MCLG | Typical Source                            |
|-------------------------------|--------------------|-------------|--------------|-------------|------|-----|------|---|
| TOTAL HALOACETIC ACIDS (HAA5) | 317 HULIN RD       | 2023 - 2024 | 16           | 9.8 - 14.4  | ppb  | 60  | 0    | By-product of drinking water disinfection |
| TOTAL HALOACETIC ACIDS (HAA5) | 606 ST ETIENNE RD  | 2023 - 2024 | 15           | 12.9 - 15.8 | ppb  | 60  | 0    | By-product of drinking water disinfection |
| TOTAL HALOACETIC ACIDS (HAA5) | 702 HUVAL DRIVE    | 2023 - 2024 | 21           | 18.7 - 21.3 | ppb  | 60  | 0    | By-product of drinking water disinfection |
| TOTAL HALOACETIC ACIDS (HAA5) | COMMERCIAL PARKWAY | 2024        | 25           | 24.5        | ppb  | 60  | 0    | By-product of drinking water disinfection |

|                               |                            |             |    |             |     |    |   |   |
|-------------------------------|----------------------------|-------------|----|-------------|-----|----|---|---|
| TOTAL HALOACETIC ACIDS (HAAS) | DUCOTE @ HUVAL             | 2024        | 15 | 15.1        | ppb | 60 | 0 | By-product of drinking water disinfection |
| TOTAL HALOACETIC ACIDS (HAAS) | POST OFFICE - S. EOLA ROAD | 2023 - 2024 | 24 | 21.7 - 26   | ppb | 60 | 0 | By-product of drinking water disinfection |
| TTHM                          | 317 HULIN RD               | 2023 - 2024 | 38 | 26.6 - 40.7 | ppb | 80 | 0 | By-product of drinking water chlorination |
| TTHM                          | 606 ST ETIENNE RD          | 2023 - 2024 | 34 | 29.1 - 35.2 | ppb | 80 | 0 | By-product of drinking water chlorination |
| TTHM                          | 702 HUVAL DRIVE            | 2023 - 2024 | 38 | 36.2 - 41.5 | ppb | 80 | 0 | By-product of drinking water chlorination |
| TTHM                          | COMMERCIAL PARKWAY         | 2024        | 51 | 51.3        | ppb | 80 | 0 | By-product of drinking water chlorination |
| TTHM                          | DUCOTE @ HUVAL             | 2024        | 32 | 32.2        | ppb | 80 | 0 | By-product of drinking water chlorination |
| TTHM                          | POST OFFICE - S. EOLA ROAD | 2023 - 2024 | 47 | 42.5 - 50.9 | ppb | 80 | 0 | By-product of drinking water chlorination |

+++++Environmental Protection Agency Required Health Effects Language+++++  
Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised people such as those with cancer undergoing chemotherapy, people who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. CITY OF BROUSSARD WATER SYSTEM is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact CITY OF BROUSSARD WATER SYSTEM and RAY BOURQUE BUS Phone: 337-837-6681. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

There are no additional required health effects notices.

+++++

Thank you for allowing us to continue providing your family with clean, quality water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers.









We at the CITY OF BROUSSARD WATER SYSTEM work around the clock to provide top quality drinking water to every tap. We ask that all our customers help us protect and conserve our water sources, which are the heart of our community, our way of life, and our children's future. **The water system grade for the City of Broussard Water System is 105/100 A+.** Additional information on the water system can be found at [www.ldh.la.gov/watergrade](http://www.ldh.la.gov/watergrade). Please call our office if you have questions.

**CITY OF BROUSSARD WATER SYSTEM**

Parish: LAFAYETTE

PWSID: LA1055003

**2024 Water Grade**

|   |   |                   |
|---|---|-------------------|
| <br><b>Federal Water Quality</b>         | <p>Points deducted for federal violations, which include Treatment Technique and Maximum Contaminant Level Violations, may pose a public health risk over an extended period of time.</p> <p>Max of 30 points</p>   | <p><b>-0</b></p>  |
| <br><b>State Water Quality</b>           | <p>Points deducted for state violations, which include no water operator, inadequate water disinfection, and boil notices and water outages, may lead to other issues of concern if not resolved.</p> <p>Max of 10 points</p>   | <p><b>-0</b></p>  |
| <br><b>Financial Sustainability</b>      | <p>Points deducted for lack of financial sustainability which can affect operations and maintenance of the water system. An effective water rate can provide for the repair, maintenance, and future replacement of infrastructure.</p> <p>Max of 10 points</p>       | <p><b>-0</b></p>  |
| <br><b>Operations &amp; Maintenance</b> | <p>Points deducted for operation and maintenance deficiencies noted during water system inspections, which may affect the water quality being distributed to consumers.</p> <p>Max of 15 points</p>   | <p><b>-0</b></p>  |
| <br><b>Infrastructure</b>              | <p>Points deducted for infrastructure deficiencies noted during water system inspections, which may lead to unsafe drinking water and/or water service disruption.</p> <p>Max of 20 points</p>  | <p><b>-5</b></p>  |
| <br><b>Customer Satisfaction</b>       | <p>Points deducted for customer complaints received by the water system and/or the Louisiana Department of Health, which are confirmed to be a water quality or quantity issue in the water system.</p> <p>Max of 10 points</p>                                       | <p><b>-0</b></p>  |
| <br><b>Secondary Contaminants</b>      | <p>Points deducted for levels of iron and/or manganese greater than the secondary maximum contaminant levels. These levels do not pose a health risk but may cause undesirable water quality issues.</p> <p>Max of 5 points</p>                                       | <p><b>-0</b></p>  |
| <br><b>BONUS</b>                       | <p>Points granted for having an asset management plan; a storage assessment and maintenance program; well assessment &amp; maintenance program; participation in management training; or participation in a capacity development program.</p> <p>Max of 10 points</p> | <p><b>+10</b></p> |

| Standard                        | Standard Maximum | Point Deductions | Detailed Assessment of Standards   |     | System Deductions |
|---------------------------------|------------------|------------------|--|-----|-------------------|
| Federal Water Quality           | -30              | 5 each           | Maximum contaminant level violations   | 0   | -0                |
|                                 |                  | 5 each           | Treatment technique violations for Lead and Copper Rule  | 0   |                   |
|                                 |                  | 10               | Is the system non-compliant with an administrative order?  | No  |                   |
| State Water Quality             | -10              | 1 each           | Chlorine violations  | 0   | -0                |
|                                 |                  | 5                | Does the water system have an operator?  | Yes |                   |
|                                 |                  | 5 each           | Water outages and/or boil notices  | 0   |                   |
| Financial Sustainability        | -10              | 5                | Did the system submit an acceptable rate study or implement an adequate rate?  | Yes | -0                |
|                                 |                  | 5                | Did the water system submit an acceptable audit?   | Yes |                   |
|                                 |                  | 10               | Is the system under a fiscal administrator for poor financial management practices?  | No  |                   |
|                                 |                  | 5                | Are there other negative circumstances that affect fiscal control of the water system?   | No  |                   |
| Operations & Maintenance        | -15              | 3 each           | Unresolved significant deficiencies  | 0   | -0                |
| Infrastructure                  | -20              | 5 each           | Unresolved significant deficiencies  | 1   | -5                |
| Customer Satisfaction           | -10              | 1 each           | Valid water complaints reported  | 0   | -0                |
|                                 |                  | 10               | Did the system submit a water complaint log?   | Yes |                   |
| Secondary Contaminants          | -5               | 5                | Manganese and/or Iron level(s) over the secondary maximum contaminant level(s)   | No  | -0                |
| Bonus                           | +10              | 5 each           | Asset management plan, storage or well assessment & maintenance plan, participation in capacity development or management training | 2   | +10               |
| <b>Total Deductions + Bonus</b> |                  |                  |  |     | 5                 |
| <b>Score</b>                    |                  |                  |  |     | 105 / 100 = 105%  |



**ANALYTICAL RESULTS**

*Broussard Purchased Water System*

Project: UCMR5\_SE1\_May2024\_RS2

Pace Project No.: 35895106

Sample: 10001 Connection to Lafayette *Albertsons Pkwy* Lab ID: 35895106001 Collected: 07/29/24 14:25 Received: 07/30/24 11:50 Matrix: Drinking Water

| Parameters   | Results | Units | PQL    | MDL    | DF | Prepared       | Analyzed       | CAS No.     | Qual |
|--|---------|-------|--------|--------|----|----------------|----------------|-------------|------|
| <b>533 PFAS Compounds, UCMR</b>                            |         |       |        |        |    |                |                |             |      |
| Analytical Method: EPA 533 Preparation Method: EPA 533     |         |       |        |        |    |                |                |             |      |
| Initial Volume/Weight: 280.37 mL Final Volume/Weight: 1 mL |         |       |        |        |    |                |                |             |      |
| Pace Analytical Services - Ormond Beach                    |         |       |        |        |    |                |                |             |      |
| 11CI-PF3OUdS   | 0.0015U | ug/L  | 0.0045 | 0.0015 | 1  | 08/01/24 09:45 | 08/02/24 21:01 | 763051-92-9 |      |
| 4:2 FTS  | 0.0009U | ug/L  | 0.0027 | 0.0009 | 1  | 08/01/24 09:45 | 08/02/24 21:01 | 757124-72-4 |      |
| 6:2 FTS  | 0.0015U | ug/L  | 0.0045 | 0.0015 | 1  | 08/01/24 09:45 | 08/02/24 21:01 | 27619-97-2  |      |
| 8:2 FTS  | 0.0015U | ug/L  | 0.0045 | 0.0015 | 1  | 08/01/24 09:45 | 08/02/24 21:01 | 39108-34-4  |      |
| 9CI-PF3ONS   | 0.0006U | ug/L  | 0.0018 | 0.0006 | 1  | 08/01/24 09:45 | 08/02/24 21:01 | 756426-58-1 |      |
| ADONA  | 0.0009U | ug/L  | 0.0027 | 0.0009 | 1  | 08/01/24 09:45 | 08/02/24 21:01 | 919005-14-4 |      |
| HFPO-DA  | 0.0015U | ug/L  | 0.0045 | 0.0015 | 1  | 08/01/24 09:45 | 08/02/24 21:01 | 13252-13-6  |      |
| NFDHA  | 0.0059U | ug/L  | 0.018  | 0.0059 | 1  | 08/01/24 09:45 | 08/02/24 21:01 | 151772-58-6 |      |
| PFBS   | 0.0009U | ug/L  | 0.0027 | 0.0009 | 1  | 08/01/24 09:45 | 08/02/24 21:01 | 375-73-5    |      |
| PFDA   | 0.0009U | ug/L  | 0.0027 | 0.0009 | 1  | 08/01/24 09:45 | 08/02/24 21:01 | 335-76-2    |      |
| PFHxA  | 0.0009U | ug/L  | 0.0027 | 0.0009 | 1  | 08/01/24 09:45 | 08/02/24 21:01 | 307-24-4    |      |
| PFBA   | 0.0015U | ug/L  | 0.0045 | 0.0015 | 1  | 08/01/24 09:45 | 08/02/24 21:01 | 375-22-4    |      |
| PFEESA   | 0.0009U | ug/L  | 0.0027 | 0.0009 | 1  | 08/01/24 09:45 | 08/02/24 21:01 | 113507-82-7 |      |
| PFHpS  | 0.0009U | ug/L  | 0.0027 | 0.0009 | 1  | 08/01/24 09:45 | 08/02/24 21:01 | 375-92-8    |      |
| PFMBA  | 0.0009U | ug/L  | 0.0027 | 0.0009 | 1  | 08/01/24 09:45 | 08/02/24 21:01 | 863090-89-5 |      |
| PFMPA  | 0.0012U | ug/L  | 0.0036 | 0.0012 | 1  | 08/01/24 09:45 | 08/02/24 21:01 | 377-73-1    |      |
| PFPeA  | 0.0009U | ug/L  | 0.0027 | 0.0009 | 1  | 08/01/24 09:45 | 08/02/24 21:01 | 2706-90-3   |      |
| PFPeS  | 0.0012U | ug/L  | 0.0036 | 0.0012 | 1  | 08/01/24 09:45 | 08/02/24 21:01 | 2706-91-4   |      |
| PFDoA  | 0.0009U | ug/L  | 0.0027 | 0.0009 | 1  | 08/01/24 09:45 | 08/02/24 21:01 | 307-55-1    |      |
| PFHpA  | 0.0009U | ug/L  | 0.0027 | 0.0009 | 1  | 08/01/24 09:45 | 08/02/24 21:01 | 375-85-9    |      |
| PFHxS  | 0.0009U | ug/L  | 0.0027 | 0.0009 | 1  | 08/01/24 09:45 | 08/02/24 21:01 | 355-46-4    |      |
| PFNA   | 0.0012U | ug/L  | 0.0036 | 0.0012 | 1  | 08/01/24 09:45 | 08/02/24 21:01 | 375-95-1    |      |
| PFOS   | 0.0012U | ug/L  | 0.0036 | 0.0012 | 1  | 08/01/24 09:45 | 08/02/24 21:01 | 1763-23-1   |      |
| PFOA   | 0.0012U | ug/L  | 0.0036 | 0.0012 | 1  | 08/01/24 09:45 | 08/02/24 21:01 | 335-67-1    |      |
| PFUnA  | 0.0006U | ug/L  | 0.0018 | 0.0006 | 1  | 08/01/24 09:45 | 08/02/24 21:01 | 2058-94-8   |      |
| <b>Surrogates</b>  |         |       |        |        |    |                |                |             |      |
| 13C24:2FTS (S)   | 132     | %     | 50-200 |        | 1  | 08/01/24 09:45 | 08/02/24 21:01 |             |      |
| 13C26:2FTS (S)   | 104     | %     | 50-200 |        | 1  | 08/01/24 09:45 | 08/02/24 21:01 |             |      |
| 13C28:2FTS (S)   | 98      | %     | 50-200 |        | 1  | 08/01/24 09:45 | 08/02/24 21:01 |             |      |
| 13C2-PFDoA (S)   | 83      | %     | 50-200 |        | 1  | 08/01/24 09:45 | 08/02/24 21:01 |             |      |
| 13C3HFPO-DA (S)  | 90      | %     | 50-200 |        | 1  | 08/01/24 09:45 | 08/02/24 21:01 |             |      |
| 13C3-PFBS (S)  | 101     | %     | 50-200 |        | 1  | 08/01/24 09:45 | 08/02/24 21:01 |             |      |
| 13C3-PFHxS (S)   | 100     | %     | 50-200 |        | 1  | 08/01/24 09:45 | 08/02/24 21:01 |             |      |
| 13C4-PFBA (S)  | 94      | %     | 50-200 |        | 1  | 08/01/24 09:45 | 08/02/24 21:01 |             |      |
| 13C4-PFHpA (S)   | 91      | %     | 50-200 |        | 1  | 08/01/24 09:45 | 08/02/24 21:01 |             |      |
| 13C5-PFHxA (S)   | 90      | %     | 50-200 |        | 1  | 08/01/24 09:45 | 08/02/24 21:01 |             |      |
| 13C5-PFPeA (S)   | 97      | %     | 50-200 |        | 1  | 08/01/24 09:45 | 08/02/24 21:01 |             |      |
| 13C6-PFDA (S)  | 84      | %     | 50-200 |        | 1  | 08/01/24 09:45 | 08/02/24 21:01 |             |      |
| 13C7-PFUdA (S)   | 84      | %     | 50-200 |        | 1  | 08/01/24 09:45 | 08/02/24 21:01 |             |      |
| 13C8-PFOA (S)  | 89      | %     | 50-200 |        | 1  | 08/01/24 09:45 | 08/02/24 21:01 |             |      |
| 13C8-PFOS (S)  | 96      | %     | 50-200 |        | 1  | 08/01/24 09:45 | 08/02/24 21:01 |             |      |
| 13C9-PFNA (S)  | 86      | %     | 50-200 |        | 1  | 08/01/24 09:45 | 08/02/24 21:01 |             |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: UCMR5\_SE1\_May2024

Pace Project No.: 35882613

Sample: 10001 Connection to Lafayette *Albertsons PKwy* Lab ID: 35882613001 Collected: 05/29/24 10:50 Received: 05/30/24 10:45 Matrix: Drinking Water

| Parameters | Results | Units | PQL | MDL | DF | Prepared | Analyzed | CAS No. | Qual |
|------------|---------|-------|-----|-----|----|----------|----------|---------|------|
|------------|---------|-------|-----|-----|----|----------|----------|---------|------|

**200.7 MET ICP, UCMR**

Analytical Method: EPA 200.7 Preparation Method: EPA 200.7  
 Initial Volume/Weight: 50 mL Final Volume/Weight: 50 mL  
 Pace Analytical Services - Ormond Beach

|         |      |      |      |     |     |                |                |           |    |
|---------|------|------|------|-----|-----|----------------|----------------|-----------|----|
| Lithium | 46.6 | ug/L | 22.5 | 7.5 | 2.5 | 06/11/24 04:28 | 06/16/24 20:14 | 7439-93-2 | N2 |
|---------|------|------|------|-----|-----|----------------|----------------|-----------|----|

**537.1 PFAS Compounds, UCMR**

Analytical Method: EPA 537.1 Preparation Method: EPA 537.1  
 Initial Volume/Weight: 272.17 mL Final Volume/Weight: 1 mL  
 Pace Analytical Services - Ormond Beach

|          |         |      |        |        |   |                |                |            |  |
|----------|---------|------|--------|--------|---|----------------|----------------|------------|--|
| NEtFOSAA | 0.0015U | ug/L | 0.0055 | 0.0015 | 1 | 06/02/24 07:56 | 06/03/24 02:07 | 2991-50-6  |  |
| NMeFOSAA | 0.0018U | ug/L | 0.0055 | 0.0018 | 1 | 06/02/24 07:56 | 06/03/24 02:07 | 2355-31-9  |  |
| PFTeDA   | 0.0025U | ug/L | 0.0073 | 0.0025 | 1 | 06/02/24 07:56 | 06/03/24 02:07 | 376-06-7   |  |
| PFTrDA   | 0.0022U | ug/L | 0.0064 | 0.0022 | 1 | 06/02/24 07:56 | 06/03/24 02:07 | 72629-94-8 |  |

**Surrogates**

|                 |     |   |        |  |   |                |                |  |  |
|-----------------|-----|---|--------|--|---|----------------|----------------|--|--|
| 13C2-PFDA (S)   | 101 | % | 70-130 |  | 1 | 06/02/24 07:56 | 06/03/24 02:07 |  |  |
| 13C2-PFHxA (S)  | 103 | % | 70-130 |  | 1 | 06/02/24 07:56 | 06/03/24 02:07 |  |  |
| NEtFOSAA-d5 (S) | 102 | % | 70-130 |  | 1 | 06/02/24 07:56 | 06/03/24 02:07 |  |  |
| HFPO-DAS (S)    | 96  | % | 70-130 |  | 1 | 06/02/24 07:56 | 06/03/24 02:07 |  |  |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

*Broussard Purchased Water System*

Project: UCMR5\_SE2\_Nov2024  
 Pace Project No.: 35916628

Sample: 10001 Connection to Lafayette *Albertsons Arkwy.* Lab ID: 35916628001 Collected: 11/04/24 10:27 Received: 11/05/24 11:40 Matrix: Drinking Water

| Parameters | Results | Units | PQL | MDL | DF | Prepared | Analyzed | CAS No. | Qual |
|------------|---------|-------|-----|-----|----|----------|----------|---------|------|
|------------|---------|-------|-----|-----|----|----------|----------|---------|------|

**200.7 MET ICP, UCMR**

Analytical Method: EPA 200.7 Preparation Method: EPA 200.7  
 Initial Volume/Weight: 50 mL Final Volume/Weight: 50 mL  
 Pace Analytical Services - Ormond Beach

|         |      |      |      |     |     |                |                |           |    |
|---------|------|------|------|-----|-----|----------------|----------------|-----------|----|
| Lithium | 34.0 | ug/L | 22.5 | 7.5 | 2.5 | 12/03/24 23:05 | 12/07/24 11:01 | 7439-93-2 | N2 |
|---------|------|------|------|-----|-----|----------------|----------------|-----------|----|

**533 PFAS Compounds, UCMR**

Analytical Method: EPA 533 Preparation Method: EPA 533  
 Initial Volume/Weight: 283.66 mL Final Volume/Weight: 1 mL  
 Pace Analytical Services - Ormond Beach

|                   |         |      |        |        |   |                |                |             |  |
|-------------------|---------|------|--------|--------|---|----------------|----------------|-------------|--|
| 11CI-PF3OUdS      | 0.0015U | ug/L | 0.0044 | 0.0015 | 1 | 11/06/24 10:20 | 11/07/24 01:09 | 763051-92-9 |  |
| 4:2 FTS           | 0.0009U | ug/L | 0.0026 | 0.0009 | 1 | 11/06/24 10:20 | 11/07/24 01:09 | 757124-72-4 |  |
| 6:2 FTS           | 0.0015U | ug/L | 0.0044 | 0.0015 | 1 | 11/06/24 10:20 | 11/07/24 01:09 | 27619-97-2  |  |
| 8:2 FTS           | 0.0015U | ug/L | 0.0044 | 0.0015 | 1 | 11/06/24 10:20 | 11/07/24 01:09 | 39108-34-4  |  |
| 9CI-PF3ONS        | 0.0006U | ug/L | 0.0018 | 0.0006 | 1 | 11/06/24 10:20 | 11/07/24 01:09 | 756426-58-1 |  |
| ADONA             | 0.0009U | ug/L | 0.0026 | 0.0009 | 1 | 11/06/24 10:20 | 11/07/24 01:09 | 919005-14-4 |  |
| HFPO-DA           | 0.0015U | ug/L | 0.0044 | 0.0015 | 1 | 11/06/24 10:20 | 11/07/24 01:09 | 13252-13-6  |  |
| NFDHA             | 0.0059U | ug/L | 0.018  | 0.0059 | 1 | 11/06/24 10:20 | 11/07/24 01:09 | 151772-58-6 |  |
| PFBS              | 0.0009U | ug/L | 0.0026 | 0.0009 | 1 | 11/06/24 10:20 | 11/07/24 01:09 | 375-73-5    |  |
| PFDA              | 0.0009U | ug/L | 0.0026 | 0.0009 | 1 | 11/06/24 10:20 | 11/07/24 01:09 | 335-76-2    |  |
| PFHxA             | 0.0009U | ug/L | 0.0026 | 0.0009 | 1 | 11/06/24 10:20 | 11/07/24 01:09 | 307-24-4    |  |
| PFBA              | 0.0015U | ug/L | 0.0044 | 0.0015 | 1 | 11/06/24 10:20 | 11/07/24 01:09 | 375-22-4    |  |
| PFEESA            | 0.0009U | ug/L | 0.0026 | 0.0009 | 1 | 11/06/24 10:20 | 11/07/24 01:09 | 113507-82-7 |  |
| PFHpS             | 0.0009U | ug/L | 0.0026 | 0.0009 | 1 | 11/06/24 10:20 | 11/07/24 01:09 | 375-92-8    |  |
| PFMBA             | 0.0009U | ug/L | 0.0026 | 0.0009 | 1 | 11/06/24 10:20 | 11/07/24 01:09 | 863090-89-5 |  |
| PFMPA             | 0.0012U | ug/L | 0.0035 | 0.0012 | 1 | 11/06/24 10:20 | 11/07/24 01:09 | 377-73-1    |  |
| PFPeA             | 0.0009U | ug/L | 0.0026 | 0.0009 | 1 | 11/06/24 10:20 | 11/07/24 01:09 | 2706-90-3   |  |
| PFPeS             | 0.0012U | ug/L | 0.0035 | 0.0012 | 1 | 11/06/24 10:20 | 11/07/24 01:09 | 2706-91-4   |  |
| PFDaA             | 0.0009U | ug/L | 0.0026 | 0.0009 | 1 | 11/06/24 10:20 | 11/07/24 01:09 | 307-55-1    |  |
| PFHpA             | 0.0009U | ug/L | 0.0026 | 0.0009 | 1 | 11/06/24 10:20 | 11/07/24 01:09 | 375-85-9    |  |
| PFHxS             | 0.0009U | ug/L | 0.0026 | 0.0009 | 1 | 11/06/24 10:20 | 11/07/24 01:09 | 355-46-4    |  |
| PFNA              | 0.0012U | ug/L | 0.0035 | 0.0012 | 1 | 11/06/24 10:20 | 11/07/24 01:09 | 375-95-1    |  |
| PFOS              | 0.0012U | ug/L | 0.0035 | 0.0012 | 1 | 11/06/24 10:20 | 11/07/24 01:09 | 1763-23-1   |  |
| PFOA              | 0.0012U | ug/L | 0.0035 | 0.0012 | 1 | 11/06/24 10:20 | 11/07/24 01:09 | 335-67-1    |  |
| PFUnA             | 0.0006U | ug/L | 0.0018 | 0.0006 | 1 | 11/06/24 10:20 | 11/07/24 01:09 | 2058-94-8   |  |
| <b>Surrogates</b> |         |      |        |        |   |                |                |             |  |
| 13C24:2FTS (S)    | 117     | %    | 50-200 |        | 1 | 11/06/24 10:20 | 11/07/24 01:09 |             |  |
| 13C26:2FTS (S)    | 104     | %    | 50-200 |        | 1 | 11/06/24 10:20 | 11/07/24 01:09 |             |  |
| 13C28:2FTS (S)    | 100     | %    | 50-200 |        | 1 | 11/06/24 10:20 | 11/07/24 01:09 |             |  |
| 13C2-PFDaA (S)    | 88      | %    | 50-200 |        | 1 | 11/06/24 10:20 | 11/07/24 01:09 |             |  |
| 13C3HFPO-DA(S)    | 98      | %    | 50-200 |        | 1 | 11/06/24 10:20 | 11/07/24 01:09 |             |  |
| 13C3-PFBS (S)     | 109     | %    | 50-200 |        | 1 | 11/06/24 10:20 | 11/07/24 01:09 |             |  |
| 13C3-PFHxA (S)    | 107     | %    | 50-200 |        | 1 | 11/06/24 10:20 | 11/07/24 01:09 |             |  |
| 13C4-PFBA (S)     | 98      | %    | 50-200 |        | 1 | 11/06/24 10:20 | 11/07/24 01:09 |             |  |
| 13C4-PFHpA (S)    | 102     | %    | 50-200 |        | 1 | 11/06/24 10:20 | 11/07/24 01:09 |             |  |
| 13C5-PFHxA (S)    | 100     | %    | 50-200 |        | 1 | 11/06/24 10:20 | 11/07/24 01:09 |             |  |
| 13C5-PFPeA (S)    | 103     | %    | 50-200 |        | 1 | 11/06/24 10:20 | 11/07/24 01:09 |             |  |
| 13C6-PFDA (S)     | 96      | %    | 50-200 |        | 1 | 11/06/24 10:20 | 11/07/24 01:09 |             |  |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: UCMR5\_SE2\_Nov2024  
 Pace Project No.: 35916628

Sample: 10001 Connection to Lafayette *Albertsons PKWY.* Lab ID: 35916628001 Collected: 11/04/24 10:27 Received: 11/05/24 11:40 Matrix: Drinking Water

| Parameters   | Results        | Units | PQL    | MDL    | DF | Prepared       | Analyzed       | CAS No.    | Qual |
|--|----------------|-------|--------|--------|----|----------------|----------------|------------|------|
| <b>533 PFAS Compounds, UCMR</b>                            |                |       |        |        |    |                |                |            |      |
| Analytical Method: EPA 533 Preparation Method: EPA 533     |                |       |        |        |    |                |                |            |      |
| Initial Volume/Weight: 283.66 mL Final Volume/Weight: 1 mL |                |       |        |        |    |                |                |            |      |
| Pace Analytical Services - Ormond Beach                    |                |       |        |        |    |                |                |            |      |
| <b>Surrogates</b>  |                |       |        |        |    |                |                |            |      |
| 13C7-PFUdA (S)   | 92             | %     | 50-200 |        | 1  | 11/06/24 10:20 | 11/07/24 01:09 |            |      |
| 13C8-PFOA (S)  | 98             | %     | 50-200 |        | 1  | 11/06/24 10:20 | 11/07/24 01:09 |            |      |
| 13C8-PFOS (S)  | 105            | %     | 50-200 |        | 1  | 11/06/24 10:20 | 11/07/24 01:09 |            |      |
| 13C9-PFNA (S)  | 98             | %     | 50-200 |        | 1  | 11/06/24 10:20 | 11/07/24 01:09 |            |      |
| <b>537.1 PFAS Compounds, UCMR</b>                          |                |       |        |        |    |                |                |            |      |
| Analytical Method: EPA 537.1 Preparation Method: EPA 537.1 |                |       |        |        |    |                |                |            |      |
| Initial Volume/Weight: 285.93 mL Final Volume/Weight: 1 mL |                |       |        |        |    |                |                |            |      |
| Pace Analytical Services - Ormond Beach                    |                |       |        |        |    |                |                |            |      |
| NEtFOSAA   | <b>0.0015U</b> | ug/L  | 0.0052 | 0.0015 | 1  | 11/06/24 11:16 | 11/06/24 22:53 | 2991-50-6  |      |
| NMeFOSAA   | <b>0.0017U</b> | ug/L  | 0.0052 | 0.0017 | 1  | 11/06/24 11:16 | 11/06/24 22:53 | 2355-31-9  |      |
| PFTeDA   | <b>0.0023U</b> | ug/L  | 0.0070 | 0.0023 | 1  | 11/06/24 11:16 | 11/06/24 22:53 | 376-06-7   |      |
| PFTrDA   | <b>0.0021U</b> | ug/L  | 0.0061 | 0.0021 | 1  | 11/06/24 11:16 | 11/06/24 22:53 | 72629-94-8 |      |
| <b>Surrogates</b>  |                |       |        |        |    |                |                |            |      |
| 13C2-PFDA (S)  | 102            | %     | 70-130 |        | 1  | 11/06/24 11:16 | 11/06/24 22:53 |            |      |
| 13C2-PFHxA (S)   | 104            | %     | 70-130 |        | 1  | 11/06/24 11:16 | 11/06/24 22:53 |            |      |
| NEtFOSAA-d5 (S)  | 105            | %     | 70-130 |        | 1  | 11/06/24 11:16 | 11/06/24 22:53 |            |      |
| HFPO-DAS (S)   | 101            | %     | 70-130 |        | 1  | 11/06/24 11:16 | 11/06/24 22:53 |            |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.